

DIARIO DE CALIDAD DE GAS

Calidad de Gas: S-SABGN130-TR01

Febrero 2013

Perfil de Unidad: Internal Storage

Perfil de Precisión: Precision PEMEX

Día	COMPOSICIÓN EN % VOLUMEN															Poder Calorífico	Poder Calorífico
	%C1	%C2	%C3	%nC4	%iC4	%nC5	%iC5	%neoC5	%C6	%C7	%C8	%C9	N2	C02	CO2+N2	BTU(IT)/CF	KJoule/m3
01/02/13 09:00:00	90.4457	5.6058	0.2733	0.0158	0.0166	0.0027	0.0039	0	0.0016	0.003	0.0007	0.0013	3.3344	0.2953	3.6297	1025.876	38,223.058
02/02/13 09:00:00	90.3689	5.4239	0.2324	0.0162	0.0161	0.0031	0.0044	0	0.002	0.0031	0.0008	0.0013	3.6426	0.285	3.9276	1020.8842	38,037.069
03/02/13 09:00:00	90.5723	5.359	0.2317	0.0161	0.0168	0.0027	0.004	0	0.0016	0.0026	0.0007	0.0012	3.4769	0.3145	3.7914	1021.6968	38,067.346
04/02/13 09:00:00	90.3786	5.3579	0.2303	0.017	0.0178	0.0028	0.0042	0	0.0017	0.003	0.0008	0.0013	3.6635	0.3211	3.9847	1019.7846	37,996.099
05/02/13 09:00:00	90.9015	5.3279	0.2875	0.0218	0.0263	0.0028	0.0042	0	0.0016	0.0031	0.0007	0.0013	3.1067	0.3147	3.4213	1026.452	38,244.519
06/02/13 09:00:00	90.1404	5.4256	0.2867	0.0204	0.0244	0.0029	0.0043	0	0.0019	0.0034	0.0009	0.0016	3.8266	0.2609	4.0875	1020.399	38,018.991
07/02/13 09:00:00	90.8811	4.9471	0.2717	0.0185	0.021	0.0028	0.0041	0	0.0017	0.0032	0.0008	0.0014	3.5774	0.2692	3.8466	1018.7821	37,958.747
08/02/13 09:00:00	90.0041	5.5673	0.2888	0.0203	0.0236	0.003	0.0042	0	0.0018	0.0032	0.0007	0.0013	3.8205	0.2611	4.0816	1021.52	38,060.758
09/02/13 09:00:00	89.7533	5.8517	0.354	0.024	0.029	0.003	0.0041	0	0.0017	0.0031	0.0008	0.0013	3.6918	0.2822	3.974	1025.9877	38,227.220
10/02/13 09:00:00	90.4288	5.6103	0.3348	0.0242	0.0293	0.0029	0.0042	0	0.0017	0.003	0.0008	0.0013	3.2509	0.3078	3.5586	1028.0738	38,304.946
11/02/13 09:00:00	90.7533	5.5446	0.2728	0.0181	0.0195	0.003	0.0042	0	0.0017	0.003	0.0008	0.0014	3.0705	0.3071	3.3777	1028.1085	38,306.239
12/02/13 09:00:00	90.9192	5.4121	0.2576	0.0181	0.0196	0.0028	0.0042	0	0.0016	0.0031	0.0008	0.0015	3.0377	0.3217	3.3595	1027.048	38,266.726
13/02/13 09:00:00	90.579	5.4198	0.2786	0.0199	0.0189	0.0033	0.0046	0	0.002	0.0032	0.0008	0.0014	3.3948	0.2737	3.6685	1024.3524	38,166.291
14/02/13 09:00:00	90.6622	5.4411	0.28	0.0188	0.0182	0.0031	0.0044	0	0.0018	0.0031	0.0008	0.0014	3.2908	0.2743	3.5651	1025.526	38,210.018
15/02/13 09:00:00	91.1055	5.3403	0.2342	0.0182	0.0191	0.0032	0.0046	0	0.002	0.0034	0.0009	0.0014	2.9692	0.2979	3.2671	1027.1323	38,269.867
16/02/13 09:00:00	90.7422	5.2422	0.2316	0.0193	0.0195	0.0037	0.0052	0	0.0027	0.0038	0.0013	0.0016	3.4691	0.2576	3.7267	1021.8099	38,071.560
17/02/13 09:00:00	90.0225	5.7548	0.2762	0.0173	0.0175	0.0033	0.0047	0	0.0022	0.0036	0.001	0.0015	3.627	0.2684	3.8954	1024.5376	38,173.191
18/02/13 09:00:00	90.3471	5.6009	0.316	0.023	0.023	0.003	0.005		0.001	0.002	0	0.003	3.345	0.331	3.676	1026.304	38,239.005
19/02/13 09:00:00	90.5772	5.4739	0.317	0.023	0.025	0.003	0.005		0.001	0.002	0	0.003	3.2189	0.351	3.5699	1026.449	38,244.408
20/02/13 09:00:00	90.9582	5.1929	0.276	0.022	0.024	0.003	0.005		0.001	0.002	0	0.003	3.1629	0.35	3.5129	1024.226	38,161.581
21/02/13 09:00:00	90.7561	5.2939	0.27	0.022	0.024	0.003	0.005		0.001	0.002	0	0.003	3.289	0.331	3.62	1023.797	38,145.597
22/02/13 09:00:00	90.3672	5.4919	0.356	0.037	0.032	0.005	0.007		0.001	0.002	0	0.003	3.3719	0.326	3.6979	1026.516	38,246.904
23/02/13 09:00:00	90.3401	5.5519	0.41	0.048	0.035	0.007	0.008		0.001	0.002	0	0.003	3.263	0.331	3.594	1029.272	38,349.590

DIARIO DE CALIDAD DE GAS

Calidad de Gas: S-SABGN130-TR01

Febrero 2013

Perfil de Unidad: Internal Storage

Perfil de Precisión: Precision PEMEX

Licuables	G.E.
BBL/MMPC	
2.0922	0.6022
1.848	0.6021
1.8286	0.6013
1.8431	0.6022
2.3024	0.6005
2.2872	0.6034
2.1426	0.5998
2.2851	0.604
2.7616	0.6058
2.6432	0.6029
2.1347	0.601
2.0389	0.6002
2.1915	0.6015
2.1815	0.6012
1.9038	0.5992
1.926	0.6004
2.1579	0.604
2.472	0.603
2.4933	0.602
2.2195	0.6
2.1816	0.601
2.9262	0.604
3.394	0.604

DIARIO DE CALIDAD DE GAS

Calidad de Gas: S-SABGN130-TR01

Febrero 2013

Perfil de Unidad: Internal Storage

Perfil de Precisión: Precision PEMEX

Día	COMPOSICIÓN EN % VOLUMEN															Poder Calorífico	Poder Calorífico
	%C1	%C2	%C3	%nC4	%iC4	%nC5	%iC5	%neoC5	%C6	%C7	%C8	%C9	N2	C02	CO2+N2	BTU(IT)/CF	KJoule/m3
24/02/13 09:00:00	90.7281	5.5379	0.292	0.021	0.023	0.003	0.004		0.001	0.002	0	0.003	3.029	0.356	3.385	1028.357	38,315.498
25/02/13 09:00:00	91.1591	5.0599	0.232	0.021	0.023	0.003	0.005		0.001	0.002	0	0.003	3.137	0.354	3.491	1022.734	38,105.991
26/02/13 09:00:00	91.6165	5.1099	0.2216	0.0229	0.0234	0.0036	0.005	0	0.0026	0.0037	0.0012	0.0018	2.655	0.3329	2.9879	1028.3095	38,313.728
27/02/13 09:00:00	90.7572	5.3136	0.2264	0.0226	0.0226	0.0037	0.005	0	0.0026	0.0037	0.0012	0.0017	3.3277	0.3119	3.6396	1023.2969	38,126.964
28/02/13 09:00:00	90.7485	5.3753	0.2369	0.0228	0.0227	0.0037	0.0051	0	0.0027	0.0038	0.0011	0.0016	3.2654	0.3104	3.5758	1024.5841	38,174.923
Promedios	90.6076	5.4155	0.2777	0.0218	0.0225	0.0033	0.0047	0	0.0017	0.0029	0.0006	0.0019	3.3327	0.3071	3.6398	1024.7077	38179.530

